



NOTES:

- 1 8.5' BURY HYDRANT UNLESS OTHERWISE SPECIFIED ON PLAN.
- ② 3/4" TO 1 1/2" WASHED AGGREGATE DRAINAGE PIT (2'X2'X3' DEEP)
- ③ 3/4" THREADED RODS, HYDRANT TO VALVE AND VALVE TO MAIN TEE.
- ④ RETAINER GLANDS ON ALL FITTINGS FROM MAIN TEE TO HYDRANT.
- ⑤ BLOCKING SHALL BE SOLID CONCRETE BLOCKS.
- ⑥ APPROVED GEOTEXTILE PLACED OVER DRAINAGE PIT.
- ⑦ 3' TYPICAL UNLESS OTHERWISE SPECIFIED ON PLAN.
- ⑧ RODDING NOT REQUIRED FROM HYDRANT TO VALVE IF OFFSET HYDRANT LEAD IS SPECIFIED.

DATE REVISED
03/11/16

STANDARD FIRE HYDRANT

PLATE NO.
2-02